



**TOETSING DAGLICHTTOETREDING**  
conform BB2012 / NEN 2057

ruimte nr.	ruimte	opp. (m <sup>2</sup> )	eis opp. daglicht (m <sup>2</sup> )
0.03	woonkamer	28.2	<b>2,8</b>
0.06	slaapkamer	10.7	<b>1.1</b>

**0.03 woonkamer**

kozijn	A <sub>d</sub> (m <sup>2</sup> )	A <sub>requil</sub> (m <sup>2</sup> )	aantal	totaal (m <sup>2</sup> )
A.04	1.1	0.9	2	1.8
A.08	0.8	0.7	1	0.7
A.09	2.3 + 2.1	3.8	1	3.8
A.10	1.6	1.6	1	1.6
<b>totaal</b>				<b>7.9m<sup>2</sup></b>

**VOLDOET**

**0.06 slaapkamer**

kozijn	A <sub>d</sub> (m <sup>2</sup> )	A <sub>requil</sub> (m <sup>2</sup> )	aantal	totaal (m <sup>2</sup> )
A.05	0.4	0.3	1	0.3
A.06	0.8	0.7	1	0.7
A.07	0.4	0.3	1	0.3
<b>totaal</b>				<b>1.3m<sup>2</sup></b>

**VOLDOET**